2873
3·495ha
8·64

1666
·138ha
·34

RANDALL BANK Def. Drain

Drain

Drain

0.18CA (11kV)

3763
4·183ha
10·34

Drain

4263
·287ha
·71

6559
9·039ha
22·34

TG
8
E

1256
·154ha
·38

2050
4·248ha
10·50

Pond

1049
1·020ha
2·52

ED & Ward Boy

0743
·186ha
·46

21E0506
SYCAMORE FARM
50 KVA
MD. 97/98 = 50KVA A/C(11kV)
TO BE REMOVED

Sluice

4443
·728ha
1·80

SAWNEBANK

95 PIAS(11kV)

2·8m

RESERVICE U/G 3m

PROPOSED
100 KVA PMT.
EST. MD. 20 KVA.
(DIRTY LOAD).

35 ALPEX SERVICE
INTO METER CUBICAL

5343
1·267ha
3·13

50 ACSR

2/0.1A AAAC(11kV)

MOVE SWITCH
2·8m ONTO NEW POLE

21ES378
Whaplode
Sycamore Farm
ABSD
10

PROPOSED
25KVA 1Ø PMT.
EST. MD. 98/99 = 20 KVA.

6054
·41

1925
4·050ha
10·0

Coraldene

0/2
·214ha
·53

RESERVICE 3 PROPERTIES U/G

0.4kV (11kV)

Track

3423
3·536ha
8·74

4524
1·441ha
3·56

Drain

Drain

Drain

Drain

7/2
1·829ha
4·52

Drain

RESERVICE 2 PROPERTIES U/G

Sycamore House

8854
·356ha
·88

PROPOSED
25 KVA 1Ø PMT.
EST. MD. 98/99 = 20 KVA.

2·7m

SG ACSR

6048
·235ha
·58

6045
4·545ha
11·23

9043
2·670ha
6·60

Drain

SELDER'S LANE

8174
·502ha
1·24

0020
7·699ha
19·03

SOUTH HOLLAND DC
HOUSING & PLANNING
24 APR 1998
Ref: 0427/98

DETERMINED
PLAN

Scale 1:1250 /LT, 11kV, 3ØAC+	TF01561060 (561061,310434)	ENGINEERING WARNING NOTES:	
Sheet 1 of 1	Kevin Bateman	20/04/98	

East Midlands Electricity

EAST LINCOLNSHIRE DISTRICT

Title WHAPLODE ST. CATHERINE

	EXISTING	PROPOSED	TO BE DISMANTLED
Overhead Lines Shown	33 kV, 11 kV, LV		
Underground Cables Shown	33 kV, 11 kV, LV		
Transformers Shown	G.M.T. P.M.T.		

Ord Sheet No. TF3019	Scale 1:1250	Drawn K.B.	
Based upon the Ordnance Survey with the sanction of the Controller of H.M. Stationery Office		Scheme No. 90164	
		Drg. No. 98/90164	