Online Comment

Application	H23-0556-18
Location	SYCAMORES BACK BANK WHAPLODE DROVE PE12 0TT
Proposal	Erection of pair of semi-detached dwellings

Name	Sue Armour
Address	Environmental Protection Officer SOuth Holland District Council

Date Submitted	18-06-18
For/Against	Comments

I request the following condition be applied:

a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.