Online Comment

Application	H23-0649-18
Location	Land adj. Willowcroft Ravens Bank Whaplode St Catherine PE12 6SH
Proposal	Residential development (1 no. dwelling)

Name	Sue Armour
Address	Environmental Health
Date Submitted	24-07-18
For/Against	Comments

I request the following condition be applied:

a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.