21ES053
Charity Farm
Whaplode Marsh
ABSD
S.P.

CB12 21E4638
CHARITY FARM
MOULTON MARSH

3 x 50ACSR

40ACSR (11kV)

0.04SCA (11kV)

150ACSR (11kV)

8m ALONG DRAINSIDE

3 x 50ACSR

KEEP CLEAR OF GATEWAY

White House Farm

CB12 21E0383
CROWN FARM WASHWAY ROAD
MOULTON COMMON

RE-SITE P.M.T. AND
RE-NAME WHITE HOUSE FARM

Crown Farm

95 AL/CU CNE

21E7050
PROPOSED 50KVA 3Ø PMT
CROWN FARM, WASHWAY ROAD
MOULTON COMMON

3 x 50ACSR

WASHWAY ROAD

21E7051
PROPOSED 25KVA 1Ø PMT
EST. M.D. = 15KVA
VICKERS FARM, WASHWAY ROAD
MOULTON COMMON

95 AL/CU CNE

COMPLAINT OF FLICKER (5%)

This plan is based upon the ordnance survey map by East Midlands Electricity, a division of PowerGen Energy plc with the sanction of the Controller of H.M. Stationery Office. Crown Copyright Reserved. Subject to any specific exceptions this copy must not be copied without the prior permission of the copyright owner. Any information provided by East Midlands Electricity is copyright and may not be reproduced in any form without the written permission of East Midlands Electricity.

EXISTING OVERHEAD LINE

PROPOSED OVERHEAD LINE

PROPOSED UNDERGROUND CABLE

OVERHEAD LINE TO BE DISMANTLED

MOULTON
WASHWAY ROAD

N.02763

A.T./B.E.L. 26/05/00

SC
HL
14 JUL 2000
Ref: 0756/ee

Scale 1:2500 /LV, 11kV, 33kV, 25kV, 132kV	TF33112974 (533115,329744)	
Sheet 1 of 1	Bryan Lea	26/05/2000

DETERMINED
PLAN