Online Comment

Application	H23-0832-19
Location	SYCAMORES BACK BANK WHAPLODE DROVE PE12 0TT
Proposal	Details of external materials, landscaping, archaeological details, radon gas, foul and surface water disposal (Conditions 3, 4, 5, 6, 7, 8 and 9 of H23-0556-18)

Name	Sue Armour
Address	Environmental Protection Officer SHDC
Date Submitted	24-09-19
For/Against	Comments

It is not possible to discharge condition 8 of H23-0556-18 at the current time as it relates to the potential for carbon dioxide and/ or methane gas from backfilled land in the vicinity and not to radon gas.
I strongly suggest that the applicant employs the services of reputable environmental consultant to help resolve this condition.