No 6502
PEAR TREE FARM
PROPOSED 16 K.V.A. 1Ø P.M.T.
EST. M.D. = 6 K.V.A.

25mm 1Ø SERVICE

Pearcroft Farm

Whaplode Fen

Whaplode Fen

Pump House

1.34 AC. R. (6/1/30mm)

SOUTH HOLLAND DC
HOUSING & PLANNING
03 NOV 1995
Ref: 1067/95

DETERMINED PLAN

East Midlands Electricity

EAST LINCOLNSHIRE DISTRICT

Title WHAPLODE DROVE, PEAR TREE FM.

	EXISTING	PROPOSED	TO BE DISMANTLED
Overhead Lines Shown	33 kv, 11 kv, Lv	X	
Underground Cables Shown	33 kv, 11 kv, Lv		
Transformers Shown	G.M.T., P.M.T.		

Grid Sheet No. T.F.3215,6 | Scale 1:2500 | Drawn JLW

Based upon the Ordnance Survey with the sanction of the Controller of H.M. Stationery Office
CROWN COPYRIGHT RESERVED.

Scheme No. 96923
Drg. No. 95/96923
Date 24-10-95