Online Comment

Application	H23-1097-18
Location	254 High Road Whaplode Spalding PE12 6TG
Proposal	Conversion of commercial premises to 3 dwellings

Name	Sue Armour
Address	Environmental Protection Officer SHDC
Date Submitted	26-11-18
For/Against	Comments

I request the following condition be applied:
a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.