Online Comment

Application	H23-1236-18
Location	Rear: 254 High Road Whaplode Spalding PE12 6TG
Proposal	Proposed bungalow and garage

Name	Sue Armour
Address	Environmental Protection Officer SHDC
Date Submitted	14-01-19
For/Against	Comments

I request the following condition be applied:

Either:

a) i) The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.
ii) Prior to occupation, a suitably detailed ground gas verification report shall be submitted and approved in writing by the Local Planning Authority.
OR

b) The full land contamination condition should be applied.