35 HYBRID

KINGSWAYS COTTAGE

(B/T)

8436
1·709ha
4·22

(WINTERTON)

21E6995

KINGSWAYS COTTAGE

PROPOSED 16KVA 1ϕ PMT

EST. M.D. = 8KVA

Pond

2 x 50ACSR 11KV

Drain

Pond

Drain

F B

F B

7700
6·262ha
15·47

7700
1·075ha
2·66

(PARKER)

Drain

8695
166ha
·41

Shepherds Cottage

879a
077ha
19

7590
1·432ha
3·54

3 x 70XLPE 11KV

F B

35AL/CU CNE LV

(PADDOCK)

Drain

3 x 50ACSR 11KV

(B/T)

Drain

TEKITS BANK

7485
1·634ha
4·04

21E6994

SHEPHERDS COTTAGE

PROPOSED 50KVA 3ϕ PMT

EST. M.D. = 8KVA

Drain

2500
2·362ha
5·84

3 x 70XLPE 11KV

Drain 2·7m

RUNWAY

FENLAND

AIRFIELD

Signal Square

Club

Control Tower

Settlement
(site of)

A - B :-

TRANSFER 4 VARIOUS SERVICES

TO NEW L.V. MAIN AND DISMANTLE

L.V. LINE. (SOME POLES TO TRANSFER TO B.T.)

5800
·546ha
1·35

(B/T)

3 x 70XLPE 11KV

185AL/CU CNE

0.1AL (LV)

3ϕ

3ϕ

Hangar

B.M 3·35

Tank

Whaplode Lodge

1ϕ

1ϕ

0.1AL (LV)

185AL/CU CNE

2·5AL (LV)

379
·023ha
13

Pond

Track

Stone

4500
·930ha
Stone 2·45

GF10 21E0902
WHAPLODE LODGE
100KVA PMT
M.D. = 45KVA
Stone

Guide Post 1
2·5m

Letter Box

4500 0.04SCA (11KV)

4500
·063ha
14

5300
·542ha
1·34

5300
6·378ha
15·76

JOINT CONSTRUCTION

6203
·117ha
29

6241
3·644ha
9·01

EXISTING OVERHEAD LINE

EXISTING UNDERGROUND CABLE

PROPOSED OVERHEAD LINE

PROPOSED UNDERGROUND CABLE

OVERHEAD LINE TO BE DISMANTLED

HOLBEACH ST JOHNS
FOX HEADINGS LANE

U.01273/4

T.S/B.E.L 14/12/99.

SOUTH HOUSIN

Scale 1:1250 /LV, 11kV, 33kV, 25kV, 132kV	TF33151811 (533155,316117)	
Sheet 1 of 1	Bryan Lea	14/12/1999